



Product certificate K14032/04

Issued 2023-02-01

Replaces K14032/03

Page 1 of 2

Vapour recovery coupler for tank installations

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

MADIC industries

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K917/02 "Vapour recovery coupler for tank installations" dated 2010-05-07 inclusive amendment sheet dated 2015-09-01.

Ron Scheepers
Kiwa

Publication of this certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

Kiwa Nederland B.V.

Sir Winston Churchillaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
NL.Kiwa.info@Kiwa.com

www.kiwa.nl



Supplier

MADIC industries
1155 Avenue Jean-Baptiste Godin
33240 SAINT-ANDRÉ-DE-CUBZAC
France
Tel. +33 5 57 80 80 80
contact.industries@madic.com
www.groupe.madic.com

Representative

Lutters Handel B.V.
Mercuriusweg 13
6971 GW BRUMMEN (Gld.)
Nederland
Tel. +31(0)57 55 62 545
lutters@luttershandel.nl
www.luttershandel.nl

Certification process
consists of initial and
regular assessment of:

- quality system
- product

Vapour recovery coupler for tank installations

Technical specification

Vapour recovery coupler, type and specifications

Type	diameter	mm	
	100 mm	DN 100	Camlock
	80 mm	DN 80	Camlock
	80 mm	DN 100	Camlock

Application and use

The vapour recovery couplers are intended to be applied in storage installations for liquid petroleum products, where the vapour of liquid petroleum is returned from the storage installation to the road tank vehicle (stage 1).

The tank installations are intended for the storage of liquid petroleum products in underground storage installations under atmospheric pressure and ambient temperature.

Marking

The products are marked with the Kiwa-mark.

Place of the mark: on body of vapour recovery coupler.

Compulsory specifications:

- manufacturer's name or mark;
- type and diameter identification;
- factory production number and identification number / date of production;
- Kiwa-mark.

Method of marking:

- non-erasable;
- clearly visible.

Recommendations for customers

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- MADIC industries

and, if necessary,

- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.